



IES INDOOR REPORT

PHOTOMETRIC FILENAME : P40-LED4-HO-NS-D2.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
 [TEST] LLI 0308-08D
 [TESTLAB] LIGHT LABORATORY INC
 [ISSUE DATE] 4/1/2008
 [MANUFAC] PRUDENTIAL LIGHTING
 [LUMCAT] D2
 [LUMINAIRE] 48-1/4"L. X 4"W. X 4" H. INDIRECT LUMINAIRE
 [MORE] WHITE REFLECTOR
 [BALLASTCAT]
 [BALLAST]
 [LAMPPOSITION]
 [LAMPCAT]
 [_LAMPLUM]
 [_INPUT] 120VAC

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	4784
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	100
Total Luminaire Watts	48
Ballast Factor	1.00
CIE Type	Indirect
Spacing Criterion (0-180)	N.A.
Spacing Criterion (90-270)	N.A.
Spacing Criterion (Diagonal)	N.A.
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	4.00 ft
Luminous Width (90-270)	0.31 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	0	0	0
55	0	0	0
65	0	0	0
75	0	0	0
85	0	0	0

IES INDOOR REPORT
PHOTOMETRIC FILENAME : P40-LED4-HO-NS-D2.IES

CANDELA TABULATION

	0.0	22.5	45.0	67.5	90.0
0	0	0	0	0	0
5	0	0	0	0	0
15	0	0	0	0	0
25	0	0	0	0	0
35	0	0	0	0	0
45	0	0	0	0	0
55	0	0	0	0	0
65	0	0	0	0	0
75	0	0	0	0	0
85	0	0	0	0	0
90	0	0	0	0	0
95	75	111	112	110	109
105	322	390	388	374	369
115	577	672	675	651	639
125	815	908	940	915	899
135	1025	1099	1140	1129	1117
145	1202	1258	1292	1286	1280
155	1332	1370	1382	1369	1361
165	1431	1449	1431	1393	1378
175	1476	1473	1426	1372	1352
180	1395	1395	1395	1395	1395

IES INDOOR REPORT
PHOTOMETRIC FILENAME : P40-LED4-HO-NS-D2.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	0.00	N.A.	0.00
0-30	0.00	N.A.	0.00
0-40	0.00	N.A.	0.00
0-60	0.00	N.A.	0.00
0-80	0.00	N.A.	0.00
0-90	0.00	N.A.	0.00
10-90	0.00	N.A.	0.00
20-40	0.00	N.A.	0.00
20-50	0.00	N.A.	0.00
40-70	0.00	N.A.	0.00
60-80	0.00	N.A.	0.00
70-80	0.00	N.A.	0.00
80-90	0.00	N.A.	0.00
90-110	288.29	N.A.	6.00
90-120	816.20	N.A.	17.10
90-130	1554.37	N.A.	32.50
90-150	3236.96	N.A.	67.70
90-180	4784.39	N.A.	100.00
110-180	4496.1	N.A.	94.00
0-180	4784.39	N.A.	100.00

Total Luminaire Efficiency = N.A.%

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	0.00
10-20	0.00
20-30	0.00
30-40	0.00
40-50	0.00
50-60	0.00
60-70	0.00
70-80	0.00
80-90	0.00
90-100	29.09
100-110	259.20
110-120	527.91
120-130	738.17
130-140	845.18
140-150	837.41
150-160	721.79
160-170	521.85
170-180	303.79


IES INDOOR REPORT
PHOTOMETRIC FILENAME : P40-LED4-HO-NS-D2.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	95	95	95	95	81	81	81	81	56	56	56	32	32	32	10	10	10	0
1	87	83	79	76	74	71	68	65	48	47	45	28	27	26	9	9	8	0
2	79	72	66	62	67	62	57	53	42	40	37	24	23	22	8	7	7	0
3	72	63	56	51	61	54	49	44	37	34	31	21	20	18	7	6	6	0
4	65	56	48	43	56	48	42	37	33	29	26	19	17	16	6	6	5	0
5	60	49	42	36	51	42	36	32	29	25	22	17	15	13	5	5	4	0
6	55	44	36	31	47	38	32	27	26	22	19	15	13	11	5	4	4	0
7	50	39	32	27	43	34	28	23	23	19	17	14	11	10	4	4	3	0
8	47	35	28	23	40	30	24	20	21	17	14	12	10	9	4	3	3	0
9	43	32	25	20	37	28	22	18	19	15	13	11	9	8	4	3	3	0
10	40	29	22	18	34	25	19	16	17	14	11	10	8	7	3	3	2	0

POLAR GRAPH



Maximum Candela = 1476 Located At Horizontal Angle = 0, Vertical Angle = 175
1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (175) (Through Max. Cd.)