



Lighting Sciences, Inc.  
UL Verification Services  
7826 E. Evans Rd.  
Scottsdale, Arizona 85260 USA  
P: 480-991-9260 F: 480-991-0375  
[lsi@ul.com](mailto:lsi@ul.com)



[www.lightingsciences.com](http://www.lightingsciences.com)

---

**INDEPENDENT TEST LABORATORY REPORT No. 31622**

**Description:**

PRUDENTIAL LIGHTING - 1' X 4' LED LUMINAIRE, CAT# P40-LED4HO-04-OPL  
WITH WHITE INTERIOR AND FROSTED PLASTIC FLAT LENS  
LUMINAIRE OPERATING AT 120 VAC

**The sample(s) was(were) tested in accordance with the following applied standards/regulations:**

ANSI/UL 1598-2008 Luminaires: In-Situ Temperature Measurement Test (ISTMT)

**Prepared for:**

PRUDENTIAL LIGHTING

LOS ANGELES, CA

**Approved by:**

JIM DOMIGAN

VS SUPERVISOR

MAR 21, 2013

*This report shall not be reproduced except in full without the written approval of the laboratory. The results in this report apply to the test sample(s) mentioned above at the time of the testing period only and are not to be used to indicate applicability to other similar products.*

LIGHTING SCIENCES, INC.  
7826 E. EVANS RD.  
SCOTTSDALE, AZ, USA 85260

INDEPENDENT TEST LABORATORY REPORT No. 31622

PRUDENTIAL LIGHTING - 1' X 4' LED LUMINAIRE, CAT# P40-LED4HO-04-OPL  
WITH WHITE INTERIOR AND FROSTED PLASTIC FLAT LENS  
LUMINAIRE OPERATING AT 120 VAC

LED Thermocouple Location



Driver Thermocouple Location



Test Temperature:	25.0 °C
LED Temperature:	67.0 °C
Driver Temperature:	73.2 °C
Maximum LED Current:	109.0 mA

Temperatures are offset to an ambient temperature of 25°C as described in UL1598-2008