



IES INDOOR REPORT

PHOTOMETRIC FILENAME : O-30-LED35-MO-D1.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
 [TEST] L041502501
 [TESTLAB] LIGHT LABORATORY, INC.
 [ISSUE DATE] 4/15/2015
 [MANUFAC] PRUDENTIAL LTG.
 [LUMCAT] O-30-LED35-MO-D1
 [LUMINAIRE] 37"DIA. X 5"H. LED LUMINAIRE
 [MORE] DIFFUSED LENS
 [BALLASTCAT] OSRAM OPTOTRONIC
 [BALLAST] INPUT: 120-277VAC
 [LAMPPOSITION] 0,0
 [LAMPCAT] N/A
 [OTHER] INDICATING THE CANDELA VALUES ARE ABSOLUTE AND
 [MORE] SHOULD NOT BE FACTORED FOR DIFFERENT LAMP RATINGS.
 [INPUT] 120VAC
 [TEST PROCEDURE] IESNA:LM-79-08

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	2140
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	45
Total Luminaire Watts	48
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.24
Spacing Criterion (90-270)	1.24
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Circular
Luminous Length (0-180)	2.98 ft (Diameter)
Luminous Width (90-270)	2.98 ft (Diameter)
Luminous Height	0.00 ft

IES INDOOR REPORT
PHOTOMETRIC FILENAME : O-30-LED35-MO-D1.IES

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	1067	1067	1067
55	1013	1013	1013
65	968	968	968
75	874	874	874
85	702	702	702

IES INDOOR REPORT
PHOTOMETRIC FILENAME : O-30-LED35-MO-D1.IES

CANDELA TABULATION

	0
0	771.75
5	766.71
10	754.11
15	734.58
20	707.49
25	674.10
30	634.41
35	590.31
40	541.80
45	489.51
50	434.70
55	376.74
60	323.82
65	265.23
70	205.38
75	146.79
80	91.35
85	39.69
90	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : O-30-LED35-MO-D1.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	279.95	N.A.	13.10
0-30	590.45	N.A.	27.60
0-40	959.68	N.A.	44.80
0-60	1675.75	N.A.	78.30
0-80	2093.88	N.A.	97.80
0-90	2140.36	N.A.	100.00
10-90	2067.56	N.A.	96.60
20-40	679.73	N.A.	31.80
20-50	1057.43	N.A.	49.40
40-70	978.43	N.A.	45.70
60-80	418.13	N.A.	19.50
70-80	155.77	N.A.	7.30
80-90	46.47	N.A.	2.20
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	2140.36	N.A.	100.00

Total Luminaire Efficiency = N.A.%

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	72.80
10-20	207.15
20-30	310.50
30-40	369.23
40-50	377.71
50-60	338.37
60-70	262.36
70-80	155.77
80-90	46.47
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00


IES INDOOR REPORT
PHOTOMETRIC FILENAME : O-30-LED35-MO-D1.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	99	95	106	101	97	94	97	94	91	93	91	88	90	87	85	83
2	99	90	83	78	96	88	82	77	85	79	75	82	77	73	78	75	71	69
3	90	79	71	64	87	78	70	64	75	68	63	72	66	62	69	65	61	58
4	82	70	61	55	80	69	61	54	66	59	53	64	58	53	62	56	52	50
5	76	63	54	47	74	62	53	47	59	52	46	57	51	46	56	50	45	43
6	70	56	47	41	68	56	47	41	54	46	40	52	45	40	50	44	40	38
7	65	51	42	36	63	50	42	36	49	41	36	47	41	36	46	40	35	33
8	60	47	38	32	59	46	38	32	45	37	32	43	37	32	42	36	32	30
9	56	43	35	29	55	42	34	29	41	34	29	40	33	29	39	33	29	27
10	53	40	32	26	52	39	31	26	38	31	26	37	31	26	36	30	26	24

POLAR GRAPH



Maximum Candela = 771.75 Located At Horizontal Angle = 0, Vertical Angle = 0
1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (0) (Through Max. Cd.)