



IES INDOOR REPORT

PHOTOMETRIC FILENAME : O-40-TU-HO-D1.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
 [TEST] L041502501
 [TESTLAB]
 [ISSUEDATE]
 [MANUFAC] PRUDENTIAL LTG.
 [LUMCAT] O-40-TU-MO-D1
 [LUMINAIRE] 48"DIA. X 5"H. LED LUMINAIRE
 [MORE] DIFFUSED LENS
 [BALLASTCAT] OSRAM OPTOTRONIC OT
 [LAMPPOSITION] 0,0
 [LAMPCAT] N/A
 [OTHER] INDICATING THE CANDELA VALUES ARE ABSOLUTE AND
 [MORE] SHOULD NOT BE FACTORED FOR DIFFERENT LAMP RATINGS.
 [INPUT] 120VAC
 [TEST PROCEDURE] IESNA:LM-79-08

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	5096
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	44
Total Luminaire Watts	116
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.24
Spacing Criterion (90-270)	1.24
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Circular
Luminous Length (0-180)	2.98 ft (Diameter)
Luminous Width (90-270)	2.98 ft (Diameter)
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	2541	2541	2541
55	2411	2411	2411
65	2304	2304	2304
75	2082	2082	2082
85	1672	1672	1672

IES INDOOR REPORT
PHOTOMETRIC FILENAME : O-40-TU-HO-D1.IES

CANDELA TABULATION

	<u>0</u>
0	1837.5
5	1825.5
10	1795.5
15	1749.0
20	1684.5
25	1605.0
30	1510.5
35	1405.5
40	1290.0
45	1165.5
50	1035.0
55	897.0
60	771.0
65	631.5
70	489.0
75	349.5
80	217.5
85	94.5
90	0.0

IES INDOOR REPORT
PHOTOMETRIC FILENAME : O-40-TU-HO-D1.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	666.55	N.A.	13.10
0-30	1405.83	N.A.	27.60
0-40	2284.95	N.A.	44.80
0-60	3989.89	N.A.	78.30
0-80	4985.44	N.A.	97.80
0-90	5096.09	N.A.	100.00
10-90	4922.77	N.A.	96.60
20-40	1618.4	N.A.	31.80
20-50	2517.7	N.A.	49.40
40-70	2329.6	N.A.	45.70
60-80	995.55	N.A.	19.50
70-80	370.88	N.A.	7.30
80-90	110.65	N.A.	2.20
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	5096.09	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	173.32
10-20	493.23
20-30	739.28
30-40	879.13
40-50	899.30
50-60	805.63
60-70	624.67
70-80	370.88
80-90	110.65
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00


IES INDOOR REPORT
PHOTOMETRIC FILENAME : O-40-TU-HO-D1.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	99	95	106	101	97	94	97	94	91	93	91	88	90	87	85	83
2	99	90	83	78	96	88	82	77	85	79	75	82	77	73	78	75	71	69
3	90	79	71	64	87	78	70	64	75	68	63	72	66	62	69	65	61	58
4	82	70	61	55	80	69	61	54	66	59	53	64	58	53	62	56	52	50
5	76	63	54	47	74	62	53	47	59	52	46	57	51	46	56	50	45	43
6	70	56	47	41	68	56	47	41	54	46	40	52	45	40	50	44	40	38
7	65	51	42	36	63	50	42	36	49	41	36	47	41	36	46	40	35	33
8	60	47	38	32	59	46	38	32	45	37	32	43	37	32	42	36	32	30
9	56	43	35	29	55	42	34	29	41	34	29	40	33	29	39	33	29	27
10	53	40	32	26	52	39	31	26	38	31	26	37	31	26	36	30	26	24

POLAR GRAPH



Maximum Candela = 1837.5 Located At Horizontal Angle = 0, Vertical Angle = 0
1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (0) (Through Max. Cd.)