

IES INDOOR REPORT

PHOTOMETRIC FILENAME : P4018-LED35-LO-D1.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
[TEST] L041505601
[TESTLAB] LIGHT LABORATORY, INC.
[ISSUE DATE]
[MANUFAC] PRUDENTIAL LTG.
[LUMCAT] P3918 or 4018-LED35-LO-D1
[LUMINAIRE] 19-1/4"DIA. X 5"H. LED LUMINAIRE
[MORE] DIFFUSED LENS
[BALLASTCAT] OSRAM OPTOTRONIC
[BALLAST] INPUT: 120-277VAC
[LAMPPOSITION] 0,0
[LAMPCAT] N/A
[OTHER] INDICATING THE CANDELA VALUES ARE ABSOLUTE AND
[MORE] SHOULD NOT BE FACTORED FOR DIFFERENT LAMP RATINGS.

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1369
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	81
Total Luminaire Watts	17
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.36
Basic Luminous Shape	Circular
Luminous Length (0-180)	2.04 ft (Diameter)
Luminous Width (90-270)	2.04 ft (Diameter)
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	1483	1483	1483
55	1418	1418	1418
65	1342	1342	1342
75	1115	1115	1115
85	698	698	698

IES INDOOR REPORT
PHOTOMETRIC FILENAME : P4018-LED35-LO-D1.IES

CANDELA TABULATION

	<u>0</u>
0	488.48
5	485.47
10	478.59
15	466.55
20	451.07
25	430.86
30	407.64
35	380.98
40	351.31
45	318.63
50	284.23
55	247.25
60	212.85
65	172.43
70	129.86
75	87.72
80	48.59
85	18.49
90	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : P4018-LED35-LO-D1.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	177.82	N.A.	13.00
0-30	376.43	N.A.	27.50
0-40	614.74	N.A.	44.90
0-60	1082.51	N.A.	79.10
0-80	1346.06	N.A.	98.30
0-90	1369.35	N.A.	100.00
10-90	1323.22	N.A.	96.60
20-40	436.92	N.A.	31.90
20-50	682.78	N.A.	49.90
40-70	637.98	N.A.	46.60
60-80	263.55	N.A.	19.20
70-80	93.34	N.A.	6.80
80-90	23.29	N.A.	1.70
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	1369.35	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	46.13
10-20	131.69
20-30	198.61
30-40	238.31
40-50	245.86
50-60	221.91
60-70	170.20
70-80	93.34
80-90	23.29
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : P4018-LED35-LO-D1.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	100	96	106	102	98	94	98	94	91	94	91	89	90	88	86	84
2	99	91	84	78	96	89	82	77	85	80	75	82	77	74	79	75	72	70
3	90	80	71	65	88	78	70	64	75	68	63	72	67	62	70	65	61	59
4	82	70	62	55	80	69	61	54	67	59	54	64	58	53	62	57	52	50
5	76	63	54	47	74	62	53	47	60	52	46	58	51	46	56	50	45	43
6	70	57	48	41	68	56	47	41	54	46	41	52	45	40	51	45	40	38
7	65	51	43	36	63	51	42	36	49	41	36	48	41	36	46	40	35	33
8	60	47	38	32	59	46	38	32	45	37	32	44	37	32	42	36	32	30
9	56	43	35	29	55	42	34	29	41	34	29	40	34	29	39	33	29	27
10	53	40	32	26	52	39	32	26	38	31	26	37	31	26	36	30	26	24

IES INDOOR REPORT
PHOTOMETRIC FILENAME : P4018-LED35-LO-D1.IES

UGR TABLE - CORRECTED

Reflectances

Ceiling Cavity	70	70	50	50	30	70	70	50	50	30
Walls	50	30	50	30	30	50	30	50	30	30
Floor Cavity	20	20	20	20	20	20	20	20	20	20

Room Size UGR Viewed Crosswise

X=2H	Y=2H	12.6	14.2	13.0	14.6	14.9	12.6	14.2	13.0	14.6	14.9
	3H	14.4	15.9	14.8	16.2	16.6	14.4	15.9	14.8	16.2	16.6
	4H	15.0	16.4	15.4	16.8	17.1	15.0	16.4	15.4	16.8	17.1
	6H	15.4	16.7	15.9	17.1	17.5	15.4	16.7	15.9	17.1	17.5
	8H	15.5	16.8	16.0	17.2	17.6	15.5	16.8	16.0	17.2	17.6
	12H	15.6	16.8	16.1	17.2	17.6	15.6	16.8	16.1	17.2	17.6

UGR Viewed Endwise


4H	2H	13.3	14.6	13.7	15.0	15.4	13.3	14.6	13.7	15.0	15.4
	3H	15.2	16.4	15.7	16.8	17.2	15.2	16.4	15.7	16.8	17.2
	4H	16.0	17.0	16.4	17.5	17.9	16.0	17.0	16.4	17.5	17.9
	6H	16.5	17.4	17.0	17.9	18.3	16.5	17.4	17.0	17.9	18.3
	8H	16.7	17.5	17.1	18.0	18.4	16.7	17.5	17.1	18.0	18.4
	12H	16.8	17.6	17.3	18.0	18.5	16.8	17.6	17.3	18.0	18.5

8H	4H	16.3	17.1	16.7	17.6	18.0	16.3	17.1	16.7	17.6	18.0
	6H	16.9	17.6	17.4	18.1	18.6	16.9	17.6	17.4	18.1	18.6
	8H	17.1	17.8	17.6	18.3	18.8	17.1	17.8	17.6	18.3	18.8
	12H	17.3	17.9	17.8	18.3	18.9	17.3	17.9	17.8	18.3	18.9

12H	4H	16.3	17.1	16.8	17.6	18.0	16.3	17.1	16.8	17.6	18.0
	6H	17.0	17.6	17.5	18.1	18.6	17.0	17.6	17.5	18.1	18.6
	8H	17.2	17.8	17.7	18.3	18.8	17.2	17.8	17.7	18.3	18.8

Maximum UGR = 18.9

POLAR GRAPH



Maximum Candela = 488.48 Located At Horizontal Angle = 0, Vertical Angle = 0
1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)
2 - Horizontal Cone Through Vertical Angle (0) (Through Max. Cd.)