



8165 E Kaiser Blvd. Anaheim, CA 92808
p. 714.282.2270
f. 714.676.5558

Test #: L041411805

Date: 5/14/2014



NVLAP LAB CODE 200927-0

Test Report: L041411805

Model Number: P9040-LED35LO-FWA-TMW-SC-UNV

Report Prepared For: Prudential Lighting
1737 East 22nd Street

Test: Electrical and Photometric tests as required by the IESNA test standards.

Standards Used: Appropriate part or all test guidelines were used for test performed:
IESNA LM79: 2008 Approved Methods for Electrical and Photometric Measurements of Solid-State Lighting Products
ANSI NEMA ANSLG C78.377: 2008 Specification of the Chromaticity of Solid State Lighting Products
ANSI C82.77:2002: Harmonic Emission Limits-Related Quality Requirements for Lighting Equipment

Description of Sample: Client submitted the sample. Fixture catalog number is P9040-LED35LO-FWA-TMW-SC-UNV . Received in working and undamaged condition. No modifications were necessary.

Testing Condition: Fixture is tested with no special conditions.

Sample Arrival Date: 4/24/14

Date of Tests: 5/13/14 - 5/13/14

Seasoning of Sample SSL: No seasoning was performed in accordance with IESNA LM-79.

Equipment List

Equipment Used	Model No	Stock No	Calibration Due Date
Chroma Programmable AC Source	61604	PS-AC02	--
Yokogawa Digital Power Meter	WT210	MT-EL06-S1	01/04/15
Xitron Power Analysis System	2503AH	MT-EL01	01/09/15
BK Precision DC Power Supply	1747	PSDC-04	01/08/15
Fluke Digital Thermometer	52k/J	MT-TP02-GC	01/04/15
LLI Type C Goniophotometer System	RMG-C-MKII	CD-LL04-GC	--
LLI 2M Sphere	2MR97	CD-SN03-S2	--
LLI Spectroradiometer	SPR-3000	MT-SC01-S2	Before Use

*All Results in accordance to IESNA LM-79-2008: Approved Method for the Electrical and Photometric Testing of Solid-State Lighting.

Test Summary

Manufacturer:	Prudential Lighting
Model Number:	P9040-LED35LO-FWA-TMW-SC-UNV
LAMPCAT:	N/A
Driver Model Number:	OSRAM OPTOTRONIC OT30W/PRG1050C/UNV/DIM/L (THREE DRIVERS)
Total Lumens:	6449.38
Input Voltage (VAC/60Hz):	120.00
Input Current (Amp):	0.73
Input Power (W):	86.90
Input Power Factor:	0.99
Total Harmonic Distortion @ 120V(%):	8%
Total Harmonic Distortion @ 277V(%):	N/A
Efficacy:	74
Ambient Temperature (°F):	77.0
Stabilization Time (Hours):	0:45
Total Operating Time (Hours):	1:45
Off State Power(W):	0.00




FIG.1 LUMINAIRE



8165 E Kaiser Blvd. Anaheim, CA 92808
p. 714.282.2270
f. 714.676.5558

Test #: L041411805

Date: 5/14/2014



NVLAP LAB CODE 200927-0

Test Methods

Photometric Measurements - Goniophotometer

A Custom Light Laboratory Type C Rotating Mirror Goniophotometer was used to measure candelas(intensity) at each angle of distribution as defined by IESNA for the appropriate fixture type.

Ambient temperature is set to 25°C and is measured from the center of the fixture, within 1ft from the outside of the fixture. Temperature is maintained at 25°C throughout the testing process and the sample is stabilized for at least 30mins and longer as necessary for the sample to achieve stabilization.

Electrical measurements are measured using the listed equipment.

Spectral Measurements - Integrating Sphere

A Sensing Spectroradiometer SPR-3000, in conjunction with Light Laboratory 2 meter integrating sphere was used to measure chromaticity coordinates, correlated color temperature(CCT) and the color rendering index(CRI) for each sample.

Ambient temperature is set to 25°C and is measured from the center of the fixture, within 1ft from the outside of the fixture. Temperature is maintained at 25°C throughout the testing process and the sample is stabilized for at least 30mins and longer as necessary for the sample to achieve stabilization.

Electrical measurements are measured using the listed equipment.

Disclaimers:

This report must not be used by the customer to claim product certification, approval or endorsement by NVLAP, NIST or any agency of Federal Government.

Report Prepared by : Randy Chau

Test Report Released by:

Jeff Ahn
Engineering Manager

Test Report Reviewed by:

Steve Kang
Quality Assurance

**Attached are photometric data reports. Total number of pages: 9*

**All Results in accordance to IESNA LM-79-2008: Approved Method for the Electrical and Photometric Testing of Solid-State Lighting.*



8165 E. Kaiser Blvd. Anaheim, CA 92808
p. 714.282.2270
f. 714.676.5558

Photometric Test Report

IES INDOOR REPORT

PHOTOMETRIC FILENAME : L041411805.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
[TEST] L041411805
[TESTLAB] LIGHT LABORATORY, INC.
[ISSUEDATE] 5/14/2014
[MANUFAC] PRUDENTIAL LIGHTING
[LUMCAT] P9040-LED35LO-FWA-TMW-SC-UNV
[LUMINAIRE] 48"SQ. X 7-5/8"H. LED LUMINAIRE
[MORE] DIFFUSED LENS
[BALLASTCAT] OSRAM OPTOTRONIC OT30W/PRG1050C/UNV/DIM/L (THREE DRIVERS)
[BALLAST] INPUT: 120-277VAC, 0.31-0.15A, 50/60Hz. OUTPUT: 30W, 10-55VDC, 350-1050mA
[LAMPPOSITION] 0,0
[LAMPCAT] N/A
[OTHER] INDICATING THE CANDELA VALUES ARE ABSOLUTE AND
[MORE] SHOULD NOT BE FACTORED FOR DIFFERENT LAMP RATINGS.
[_INPUT] 120VAC, 86.90W
[_TEST PROCEDURE] IESNA:LM-79-08

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	6449
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	74
Total Luminaire Watts	86.9
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.26
Spacing Criterion (90-270)	1.26
Spacing Criterion (Diagonal)	1.38
Basic Luminous Shape	Circular
Luminous Length (0-180)	3.83 ft (Diameter)
Luminous Width (90-270)	3.83 ft (Diameter)
Luminous Height	0.00 ft

IES INDOOR REPORT
PHOTOMETRIC FILENAME : L041411805.IES

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	1959	1959	1959
55	1871	1871	1871
65	1782	1782	1782
75	1587	1587	1587
85	1403	1403	1403

IES INDOOR REPORT
PHOTOMETRIC FILENAME : L041411805.IES

CANDELA TABULATION

	<u>0</u>
0	2273
5	2260
10	2226
15	2172
20	2097
25	2005
30	1897
35	1773
40	1635
45	1484
50	1322
55	1150
60	988
65	807
70	622
75	440
80	274
85	131
90	0

IES INDOOR REPORT
PHOTOMETRIC FILENAME : L041411805.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	827.38	N.A.	12.80
0-30	1751.41	N.A.	27.20
0-40	2860.44	N.A.	44.40
0-60	5036.63	N.A.	78.10
0-80	6303.46	N.A.	97.70
0-90	6449.38	N.A.	100.00
10-90	6234.71	N.A.	96.70
20-40	2033.06	N.A.	31.50
20-50	3177.56	N.A.	49.30
40-70	2974.39	N.A.	46.10
60-80	1266.84	N.A.	19.60
70-80	468.64	N.A.	7.30
80-90	145.92	N.A.	2.30
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	6449.38	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	214.67
10-20	612.71
20-30	924.03
30-40	1109.03
40-50	1144.5
50-60	1031.69
60-70	798.20
70-80	468.64
80-90	145.92
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00


IES INDOOR REPORT
PHOTOMETRIC FILENAME : L041411805.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	109	104	99	95	106	101	97	94	97	94	91	93	90	88	90	87	85	83
2	99	90	83	77	96	88	82	76	85	79	75	81	77	73	78	75	71	69
3	90	79	71	64	87	77	70	64	74	68	62	72	66	61	69	64	60	58
4	82	70	61	54	80	69	60	54	66	59	53	64	58	52	62	56	52	50
5	76	63	53	47	73	61	53	46	59	52	46	57	51	45	55	50	45	43
6	70	56	47	41	68	55	47	41	53	46	40	52	45	40	50	44	39	37
7	65	51	42	36	63	50	42	36	49	41	36	47	40	35	46	40	35	33
8	60	47	38	32	59	46	38	32	44	37	32	43	36	32	42	36	31	29
9	56	43	34	29	55	42	34	29	41	34	29	40	33	28	39	33	28	26
10	53	39	31	26	51	39	31	26	38	31	26	37	30	26	36	30	26	24

POLAR GRAPH



Maximum Candela = 2273 Located At Horizontal Angle = 0, Vertical Angle = 0

1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)

2 - Horizontal Cone Through Vertical Angle (0) (Through Max. Cd.)